

New cycle-based formulation, cost function, and heuristics for DC OPF based controlled islanding

Tyuryukanov, Ilya; Popov, Marjan; Bos, Jorrit A.; van der Meijden, Mart A.M.M.; Terzija, Vladimir

DOI

[10.1016/j.epsr.2022.108588](https://doi.org/10.1016/j.epsr.2022.108588)

Publication date

2022

Document Version

Final published version

Published in

Electric Power Systems Research

Citation (APA)

Tyuryukanov, I., Popov, M., Bos, J. A., van der Meijden, M. A. M. M., & Terzija, V. (2022). New cycle-based formulation, cost function, and heuristics for DC OPF based controlled islanding. *Electric Power Systems Research*, 212, Article 108588. <https://doi.org/10.1016/j.epsr.2022.108588>

Important note

To cite this publication, please use the final published version (if applicable).
Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights.
We will remove access to the work immediately and investigate your claim.



New cycle-based formulation, cost function, and heuristics for DC OPF based controlled islanding

Ilya Tyuryukanov^{a,*}, Marjan Popov^a, Jorrit A. Bos^b, Mart A.M.M. van der Meijden^{a,b}, Vladimir Terzija^c

^a Faculty of EEMCS, Delft University of Technology, Delft 2628CD, Netherlands

^b TenneT TSO B.V., Arnhem 6812AR, Netherlands

^c Key Laboratory of Power System Intelligent, Dispatch and Control of Ministry of Education, School of Electrical Engineering, Shandong University, Jinan 250061, China

ARTICLE INFO

Keywords:

Controlled islanding
Integer programming
Network connectivity
DC OPF
Heuristics

ABSTRACT

This paper presents a new formulation for intentional controlled islanding (ICI) of power transmission grids based on mixed-integer linear programming (MILP) DC optimal power flow (OPF) model. We highlight several deficiencies of the most well-known formulation for this problem and propose new enhancements for their improvement. In particular, we propose a new alternative optimization objective that may be more suitable for ICI than the minimization of load shedding, a new set of island connectivity constraints, and a new set of constraints for DC OPF with switching, and a new MILP heuristic to find initial feasible solutions for ICI. It is shown that the proposed improvements help to reduce the final optimality gaps as compared to the benchmark model on several test instances.

1. Introduction

Intentional controlled islanding (ICI) is an important system integrity protection scheme (SIPS) aiming to prevent system collapse due to wide-area instability by separating the system into a set of non-interacting islands. A typical situation requiring such a control action is loss of synchronism between some parts of the system, but it can also be used to limit the spread of cascading outages, or to isolate unstable parts of the system. The high relevance of this control action is confirmed by the increasing number of blackouts around the globe [1].

From the mathematical perspective, computing the splitting boundary to separate the system into a number of self-sustained islands equates to an OPF problem with switching. Such problems are notoriously hard to solve, as OPF is nonlinear, and switching decisions are discrete, which amounts to a mixed-integer nonlinear program (MINLP). Moreover, ICI must be solved rapidly in real-time as a corrective control action for instability mitigation. For this reason, solving ICI as a MINLP is not feasible, and MILP reformulations of the original MINLP are often seen as an acceptable trade-off between accuracy and computation time.

Although multiple MILP approximations for ICI and optimal transmission switching (OTS) exist in literature (e.g., [2,3]), this paper is focused on the basic DC OPF ICI model. Our goal is to resolve the fundamental issues associated with the DC OPF ICI model to devise

the efficient computational enhancements that could also be applied to more advanced MILP-based ICI models [2–4].

We first observe that the conventional ICI objective of minimizing the total post-splitting load shedding [5,6] may often result in a poor MIP optimality gap progression if the exact optimal load shedding is close to zero. To alleviate this issue, we propose to minimize the total load-generation imbalance in the computed islands while possibly keeping the load shedding as the secondary optimization objective. Minimizing the total load-generation imbalance should limit load shedding and additionally limit the value of the rate of change of frequency (ROCOF) following the system splitting.

Our second contribution aims to improve the modeling of the islands' connectedness requirement. The previously published papers on optimization-based ICI either use artificial commodity flows to impose connectivity constraints on islands [6] or neglect this requirement [2,7]. Our proposal is to model connectivity through directed spanning trees, which aims to avoid the computationally inefficient *big-M* coefficients that accompany the commodity flow based formulation. This technique has previously been applied to enforce radiality in distribution networks [8], but our approach differs from [8].

Our third contribution addresses the *big-M* coefficients that are normally present in the DC OPF constraints related to switching decisions. We reformulate these constraints as Kirchhoff's voltage law (KVL)

* Corresponding author.

E-mail address: ilya.tyuryukanov@ieee.org (I. Tyuryukanov).

<https://doi.org/10.1016/j.epsr.2022.108588>

Received 4 October 2021; Received in revised form 17 April 2022; Accepted 2 July 2022

Available online 19 July 2022

0378-7796/© 2022 The Author(s). Published by Elsevier B.V. This is an open access article under the CC BY license (<http://creativecommons.org/licenses/by/4.0/>).

equations with additional slack variables to eliminate the uncertain voltage angle differences across an open line otherwise modeled as large big-M constants. Cycle inequalities involving KVL have been previously proposed in [9], but our work differs from [9] in several aspects. The goal of [9] was to strengthen the LP relaxation of the conventional DC optimal transmission switching (OTS) model, while our goal is the elimination of the big-M coefficients. This motivates a different modeling approach.

Our fourth contribution is a new MILP heuristic to find initial feasible solutions for DC OPF ICI. For some MIP problems, a feasible solution can be obtained trivially or in polynomial time, but the OPF ICI problem combining power flow physics and discrete decisions does not allow for a simple initialization. Obtaining an early feasible solution is crucial for the progress of a modern MIP solver, as there are efficient heuristics that are able to progressively improve the best feasible solution (e.g., the RINS heuristic). Unfortunately, we could not identify any published MILP heuristics for OPF ICI, which prompted the design of a simple yet effective method based on the LP relaxation of DC OPF ICI.

The following sections describe the above contributions in more detail. Section 2.2 introduces the used notation and the conventional benchmark DC OPF ICI model. Section 3 details our proposed model and cost function. Section 4 introduces the MILP heuristic for OPF ICI and explains how MILP is solved. Section 5 describes the test cases and presents the computational results. Section 6 concludes the paper.

2. Overview of previous results

2.1. Notations

A power network consisting of n nodes and m branches is represented by a graph with set of nodes \mathcal{V} , set of edges \mathcal{E} ($|\mathcal{E}| = m$), and set of arcs \mathcal{A} ($|\mathcal{A}| = 2m$). Power demand and power generation at node i prior to splitting are denoted as $P_{L,i}^s$ and $P_{G,i}^s$. Load demand and generation shedding to satisfy the post-splitting conditions are denoted as $P_{L,i}$ and $P_{G,S,i}$. Power flow through branch $(i, j) \in \mathcal{E}$ is defined as $p_{i,j}$, its value prior to splitting is $p_{i,j}^s$, and its limiting magnitude is $p_{i,j}^{max}$. Admittance of branch (i, j) is denoted as $b_{i,j}$. As the used model is DC OPF, reactive power is not modeled.

The splitting configuration is modeled by binary variables $x_{i,k}$ ($x_{i,k} = 1$ implies that node i is assigned to island k) and $y_{i,j}$ ($y_{i,j} = 1$ implies that branch $(i, j) \in \mathcal{E}$ is open). The total number islands is K . An important ICI requirement that promotes transient stability after splitting is to assign generators from the same coherent group to one island. Coherent groups are denoted as $\mathcal{G}_1, \dots, \mathcal{G}_K$ (i.e., each coherent group is supposed to form a separate island).

Indices i and j run over network nodes and pairs of nodes (edges or arcs). Index k runs over islands ($k = 1, \dots, K$). Superscripts $s, *, LR$ denote pre-splitting values, integral solutions of MILP programs, and linear relaxation (LR) solutions of MILP programs respectively.

2.2. Basic MILP model for DC OPF ICI

Probably the first paper proposing a MILP-based ICI strategy was [5]. Since then several related models appeared in the literature, of which the model in [7] is the most compact one. Unlike [5,10,11], the model in [7] does not use auxiliary binary variables that model the membership of edge (i, j) in island k . Instead, the edge status variables $y_{i,j}$ are used directly, which eliminates $O(mK)$ extra binary variables and constraints. However unlike most other references, the models in [2,7] neglect the islands' connectedness requirement. To avoid the deficiencies of any single existing model, a combined DC OPF ICI model is introduced below:

$$\min \quad \beta \sum_{i \in \mathcal{V}} P_{L,S,i} + \gamma \sum_{i \in \mathcal{V}} P_{G,S,i} + \mu \sum_{(i,j) \in \mathcal{E}} p_{i,j}^s y_{i,j} \quad (1a)$$

$$\sum_{k=1}^K x_{i,k} = 1, \quad \forall i \in \mathcal{V} \quad (1b)$$

$$x_{i,k} = 1, \quad \forall i \in \mathcal{G}_k, \quad \forall k \quad (1c)$$

$$x_{i,k} - x_{j,k} \leq y_{i,j}, \quad \forall (i, j) \in \mathcal{E}, \quad \forall k \quad (1d)$$

$$x_{j,k} - x_{i,k} \leq y_{i,j}, \quad \forall (i, j) \in \mathcal{E}, \quad \forall k \quad (1e)$$

$$x_{i,k} + x_{j,k} + y_{i,j} \leq 2, \quad \forall (i, j) \in \mathcal{E}, \quad \forall k \quad (1f)$$

$$\sum_{(i,j) \in \mathcal{E}} p_{i,j} - \sum_{(j,i) \in \mathcal{E}} p_{j,i} = P_{G,i}^s - P_{G,S,i} - P_{L,i}^s + P_{L,S,i}, \quad \forall i \in \mathcal{V} \quad (1g)$$

$$P_{G,S,i}^{min} \leq P_{G,S,i} \leq P_{G,S,i}^{max}, \quad \forall i \in \mathcal{V} \quad (1h)$$

$$P_{L,S,i}^{min} \leq P_{L,S,i} \leq P_{L,i}^s, \quad \forall i \in \mathcal{V} \quad (1i)$$

$$p_{i,j} \leq p_{i,j}^{max} (1 - y_{i,j}), \quad \forall (i, j) \in \mathcal{E} \quad (1j)$$

$$p_{i,j} \geq -p_{i,j}^{max} (1 - y_{i,j}), \quad \forall (i, j) \in \mathcal{E} \quad (1k)$$

$$p_{i,j} - b_{i,j}(\varphi_i - \varphi_j) \leq M_{i,j}^\varphi y_{i,j}, \quad \forall (i, j) \in \mathcal{E} \quad (1l)$$

$$p_{i,j} - b_{i,j}(\varphi_i - \varphi_j) \geq -M_{i,j}^\varphi y_{i,j}, \quad \forall (i, j) \in \mathcal{E} \quad (1m)$$

$$\varphi^{min} \leq \varphi_i \leq \varphi^{max}, \quad \forall i \in \mathcal{V} \quad (1n)$$

$$\varphi_r = 0, \quad r \in \mathcal{R} \quad (1o)$$

$$f_{i,j} \leq (n-1)(1-y_{i,j}), \quad \forall (i, j) \in \mathcal{E} \quad (1p)$$

$$f_{i,j} \geq -(n-1)(1-y_{i,j}), \quad \forall (i, j) \in \mathcal{E} \quad (1q)$$

$$\sum_{(r,k,j) \in \mathcal{E}} f_{r,k,j} - \sum_{(j,r,k) \in \mathcal{E}} f_{j,r,k} = \sum_{i \in \mathcal{V}} x_{i,k}, \quad r_k \in \mathcal{R}, \quad k = 1, \dots, K, \quad x_{r_k,k} = 1 \quad (1r)$$

$$\sum_{(i,j) \in \mathcal{E}} f_{i,j} - \sum_{(j,i) \in \mathcal{E}} f_{j,i} = -1, \quad \forall i \in \mathcal{V} \setminus \mathcal{R} \quad (1s)$$

$$x_{i,k} \in \{0, 1\}, \quad \forall i \in \mathcal{V}, \quad k = 1, \dots, K \quad (1t)$$

$$y_{i,j} \in \{0, 1\}, \quad \forall (i, j) \in \mathcal{E} \quad (1u)$$

The objective of (1) combines the relevant objectives from [5,10,11] with different weight factors. The factor β is associated with minimal load shedding, which is of great importance for ICI. While minimizing load shedding, it is important to avoid arbitrary large values of shed or disconnected generation, which is achieved by introducing the minimization of generation shedding into (1a) with the weight γ . Additionally, [10,11] use the minimization of total power flow disruption as their cost function. In our experience, this choice of cost function allows for an easier convergence to the optimum, but it cannot well enough represent the power balance within islands, which is the main challenge of ICI. However, a large power flow disruption is undesirable [12], which explains its presence in (1a) with the weight μ .

Switching constraints (1b)–(1f) ensure the separation of buses belonging to different islands from each other through open branches ($y_{i,j} = 1$). Here (1f) ensures that lines connecting buses in the same island are closed, thus precluding line switching inside islands. Because of (1f), the formulation in (1) becomes easier to solve, as its feasible region becomes more constrained. From an operational perspective, requiring both the optimal splitting cutset and optimal line switching inside of each island may be too complex and impractical during an emergency condition.

DC OPF constraints (1g)–(1m) describe the physics of DC power flow. Kirchhoff current law (KCL) is modeled by (1g), which represents the power balance at each node. Constraints (1j)–(1m) model Ohm's law under the presence of switching decisions $y_{i,j}$, which requires the introduction of the node potential variables φ_i , $\forall i \in \mathcal{V}$. When branch (i, j) is closed, $p_{i,j}$ is governed by Ohm's law. If branch (i, j) is open, $p_{i,j} = 0$ and the angle difference $(\varphi_i - \varphi_j)$ can be arbitrary. Therefore, the big-M constants $M_{i,j}^\varphi$ are needed to allow $(\varphi_i - \varphi_j)$ to take some rather large values. Additionally, the lower and upper bounds φ^{min} and

φ^{max} in (1n) can also be seen as big-M constants, as their values often cannot be estimated exactly.

Single commodity flow constraints are used to ensure the connectedness of each island in the same way as the switching constraints (1b)–(1e) ensure the separation of islands from one another. For each coherent group G_k , a root node $r_k \in G_k$, $r_k \in \mathcal{R}$ is selected, whereby \mathcal{R} is the union of root nodes of all groups. Constraint (1r) requires that the number of units of an artificial commodity produced at r_k equals the total number of nodes in island k corresponding to G_k , while constraints (1s) demand one unit of commodity to be consumed at each non-root node. The satisfaction of flow balance (1r)–(1s) requires each island to be connected. However, the upper bounds of commodity flows for each branch are not known, which prompts the usage of another big-M constant $n - 1$ in (1p)–(1q). This big-M constant could be somewhat lowered through exact calculations, but $n - 1$ is shown here to simplify the representation. Unlike [5,10], (1) does not require a separate set of commodity flow variables for each island, as it appears that a single set of m commodity flows f_{ij} can be used for all islands.

3. Proposed MILP model

3.1. DC OPF ICI using cycle-based KVL constraints

A major issue with (1) is the presence of big-M constants $M_{i,j}^\varphi$ in (1l)–(1m). While there are methods to bound these coefficients when the solution is required to contain a single connected component (e.g., [13]), no bound strengthening method is known for the disconnected networks resulting from ICI. Thus, a possibly unrealistically large value needs to be assumed for $M_{i,j}^\varphi$ in order to preserve all feasible solutions.

An alternative to Ohm's law form of power flow equations in (1l)–(1m) is to apply KVL to the entire network, while considering the switching decisions. The KVL equations are written with respect to a set of linearly independent cycles in the network, which is known as *cycle basis*. For the reasons that become clear below, it is desirable to compute the cycle basis as quickly as possible, which is achieved by using as cycle basis *fundamental cycles* induced by the network's minimal spanning tree (MST) [14]. Given cycle basis CB , the KVL alternatives of (1l)–(1m) can be formulated as follows:

$$\sum_{(i,j) \in C} \frac{p_{i,j}}{b_{i,j}} \text{sgn}(i,j) \leq \frac{1}{2} M_C \sum_{(i,j) \in C} y_{i,j}, \quad \forall C \in CB \quad (2a)$$

$$\sum_{(i,j) \in C} \frac{p_{i,j}}{b_{i,j}} \text{sgn}(i,j) \geq -\frac{1}{2} M_C \sum_{(i,j) \in C} y_{i,j}, \quad \forall C \in CB \quad (2b)$$

where $C \in CB$ is a cycle formed by undirected edges $(i,j) \in \mathcal{E}$, and function $\text{sgn}(i,j)$ takes the plus sign if edge (i,j) is aligned with the clockwise direction of C and the minus sign otherwise.

As (1f) precludes line switching inside islands, each cycle is either connected or has at least two open lines. Therefore, M_C is the sum of $|\frac{p_{i,j}^{max}}{b_{i,j}}|$, $(i,j) \in C$ minus the two smallest values of $|\frac{p_{i,j}^{max}}{b_{i,j}}|$ along C . Unlike $M_{i,j}^\varphi$, M_C can be computed exactly, but it may still be quite large for long cycles. Thus, to additionally strengthen the model, we are adding some additional KVL constraints (2) associated with cycles shorter than a certain length. All such cycles can be found in polynomial time by applying to each node techniques based on recursive node neighborhood traversal. Short cycles (e.g., up to length 7) can be found quickly before the start of the MIP solver, but enumerating longer cycles becomes increasingly computationally inefficient.

Obviously, any cycle basis of the disconnected network contains less cycles than the cycle basis of the original network. As only a small fraction of edges is opened for ICI, the majority of fundamental cycles of the disconnected network coincide with the initial fundamental cycles. However, in some cases the original fundamental cycles do not fully describe the cycle basis of the disconnected network. Thus, for each integer solution obtained during the solution process, cycles violating

(2) need to be identified, and the corresponding inequalities (2) added to the model by using MIP solver callbacks. A possible computationally efficient way to achieve this is as follows:

- (1) Compute the MST of the original network and the associated fundamental cycle basis CB_0 .
- (2) Assign close-to-zero weights to the network edges belonging to the MST.
- (3) Once an integer solution is found, compute its minimal spanning forest and the associated fundamental cycle basis CB_i (i is the solution number). The previously assigned small edge weights should promote the alignment of the newly computed cycle basis with the original one.
- (4) Check the solution for conformity with (2) (i.e., $\sum_{(i,j) \in C} \frac{p_{i,j}^*}{b_{i,j}} \text{sgn}(i,j) = 0$, $\forall C \in CB_i$).
- (5) If any cycles in CB_i violate (2), use them to add new KVL constraints (2) to the model.

Besides strengthening the model, the abovementioned KVL constraints based on extra short cycles also improve the satisfaction of (2) for the intermediate integer feasible solutions.

3.2. Island connectivity constraints

The single commodity flow constraints that are most commonly used to enforce islands' contiguity [5,6,10] have the drawback of introducing at least m auxiliary variables and large big-M constants that may lead to loose LP relaxations. In [11], two alternative methods based on multicommodity flows and network cutsets are proposed. However, these alternatives may often underperform the simple single commodity flow approach. At least the multicommodity flow method has largely theoretical importance due to the very large number of auxiliary variables that it requires [15]. The cutset-based method requires solving many max-flow min-cut problems to identify cutsets that violate connectivity, which has the time complexity of $O(mn^2)$ for a single max-flow min-cut run.

In this section, a different approach to islands' connectivity is proposed that does not involve big-M coefficients and allows to quickly find strong inequalities that ensure network connectivity. This approach is related to the studies on radiality constraints in distribution networks (e.g., [8,16]), but has some application-specific features and computational improvements. One of conditions for network connectedness is that there exists a spanning tree with $n - 1$ edges that spans all of its nodes. In general, for a network with k connected components there exists k spanning trees (one for each component) forming a *spanning forest* that includes $n - k$ edges. This observation motivates the following connectivity formulation based on rooted directed spanning trees:

$$\sum_{(i,j) \in \mathcal{A}} z_{i,j} = n - k \quad (3a)$$

$$z_{j,r} = 0, \quad \forall (j,r) \in \mathcal{A}, \quad \forall r \in \mathcal{R} \quad (3b)$$

$$\sum_{(r,j) \in \mathcal{A}} z_{r,j} \geq 1, \quad \forall r \in \mathcal{R} \quad (3c)$$

$$\sum_{(j,i) \in \mathcal{A}} z_{j,i} = 1, \quad \forall i \in \mathcal{V} \setminus \mathcal{R} \quad (3d)$$

$$z_{i,j} + z_{j,i} \leq 1 - y_{i,j}, \quad \forall (i,j) \in \mathcal{E}_C \quad (3e)$$

$$z_{i,j} + z_{j,i} = 1 - y_{i,j}, \quad \forall (i,j) \in \mathcal{E} \setminus \mathcal{E}_C \quad (3f)$$

$$\sum_{(i,j) \in C} z_{i,j} \leq |C| - 1, \quad \forall C \in \mathcal{D} \quad (3g)$$

$$z_{i,j} \in \{0, 1\}, \quad \forall (i,j) \in \mathcal{A} \quad (3h)$$

where $z_{i,j}$ and $z_{j,i}$ represent the status of arcs (i,j) and $(j,i) \in \mathcal{A}$ ($z_{i,j} = 1$ iff (i,j) is enabled).

The equalities in (3b)–(3c) define the root nodes of K coherent generator groups as root nodes of K trees each spanning one island. According to (3b)–(3c), each root node should have no incoming arcs and at least one outgoing arc. Conversely, each non-root node should have one incoming arc according to (3d). Constraints (3e)–(3f) link z and y variables. For the edges that participate in network cycles (i.e., in the cycle basis described in Section 3.1), (3e) is valid. For the rest of the edges, the stronger version (3f) can be used instead of (3e). The number of enabled arcs is constrained by (3a).

Combined constraints (3a)–(3f) can define k connected components spanned by k directed trees, or more than k connected components. In the latter case, the additional components will form directed cycles to satisfy (3a)–(3f). Therefore, cycle breaking constraints (3g) are needed to only allow spanning forests as solutions, where D is the set of all directed cycles in the network and C is a sequence of arcs in \mathcal{A} forming a directed cycle. As there are exponentially many cycles in the network, all constraints in (3g) cannot be simultaneously added to the model. Instead, only the violated inequalities (3g) are added in MIP solver callbacks that are available in most of modern MIP solvers (see Section 3.5).

3.3. Extra strengthening cycle inequalities

To further strengthen the cycle-based ICI formulation, the following *triangle inequalities* (e.g., see [17]) are added for all known cycles of the minimal length:

$$y_{i,j} - \sum_{\substack{(p,q) \in C \\ (p,q) \neq (i,j)}} y_{p,q} \leq 0, \quad \forall C \in CB, |C| = 3, \forall (i,j) \in C \quad (4)$$

3.4. Minimization of load-generation imbalance

Minimal load shedding is often chosen as the cost function of ICI, as it is highly important for utilities to minimize the loss of load. However, shedding an exact amount of load at exact bus at exact moment in time to realize the outcome of (1) may be sometimes quite challenging with the available equipment. Moreover, the optimal load shedding can be zero, in which case it will be impossible to provide a non-zero lower bound, and the integrality gap of the MIP solver will be close to 100% during the whole optimization.

Among practitioners, the notion of *balanced islands* with good load-generation balance is no less popular than the idea of minimal load shedding. Islands with good power balance would naturally limit load shedding without the need of picking specific buses, while also limiting the ROCOF value after splitting. At the same time, the total power imbalance of all islands is always non-zero and can be much easier bounded from below. Based on (1), the minimization of load generation imbalance can be formulated as follows:

$$\min \sum_{k=1}^K P_{\Delta,k} \quad (5a)$$

$$P_{\Delta,k} \geq \sum_{i \in \mathcal{V}} (P_{G,i}^s - P_{L,i}^s) x_{i,k}, \quad \forall k \quad (5b)$$

$$P_{\Delta,k} \geq \sum_{i \in \mathcal{V}} (P_{L,i}^s - P_{G,i}^s) x_{i,k}, \quad \forall k \quad (5c)$$

(1b)–(1u)

where $P_{\Delta,k}$ represents the power imbalance of island k .

The inequalities in (5b)–(5c) are constraining the absolute value $|\sum_{i \in \mathcal{V}} (P_{G,i}^s - P_{L,i}^s) x_{i,k}|$ from below for each k , while the minimization requirement (5a) constrains it from above.

Algorithm 1 Generation of cycle breaking constraints

Input: $z_{i,j}^*, \mathcal{V}, K$
Output: Set of violating directed cycles C

- 1: $G(\mathcal{V}, \mathcal{A}_G) \leftarrow$ directed graph induced by $z_{i,j}^*$
- 2: $F(\mathcal{V}, \mathcal{A}_F) \leftarrow$ spanning_forest(G)
- 3: $CC \leftarrow$ connected_components(F)
- 4: **if** $|CC| = K$ **then return** \emptyset
- 5: **end if**
- 6: $\mathcal{A}_C \leftarrow \mathcal{A}_G \setminus \mathcal{A}_F$
- 7: **for** $a_{i,j} \in \mathcal{A}_C$ **do**
- 8: $P \leftarrow$ shortest_path(F , source= j , target= i)
- 9: $C \leftarrow P \cup a_{i,j}$
- 10: $C \leftarrow C \cup C$
- 11: **end for**
- 12: **return** C

3.5. Overall solution process

The ideas from Sections 3.2–3.1 can be combined together into the following novel DC OPF ICI formulation:

$$\min \alpha \sum_{k=1}^K P_{\Delta,k} + \beta \sum_{i \in \mathcal{V}} P_{LS,i} + \gamma \sum_{i \in \mathcal{V}} P_{GS,i} + \mu \sum_{(i,j) \in \mathcal{E}} p_{i,j}^s y_{i,j} \quad (6)$$

(1b)–(1k)
(2a)–(2b)
(3a)–(3h), (4), (5b)–(5c)

The above formulation requires MILP callbacks for cycle breaking constraints (3g) to be solved efficiently. In our implementation, the violated cycle breaking constraints are easily separated using Algorithm 1 for each new integer solution.

Given an integer solution $z_{i,j}^*$, it can be considered as directed graph G . For this graph, the spanning forest F can be computed by using the standard spanning tree algorithms with loglinear time complexity. If F has k connected components, the solution is accepted, and the best integer solution gets updated. Otherwise, Algorithm 1 finds arcs that are in G , but not in F . Each such arc corresponds to a directed cycle, which allows to retrieve the full set of cycles C that violate (3g) in loglinear time.

In addition to cycle breaking constraints (3g), we are adding directed cutset constraints between the root node of each group and the remaining generators of the same group using the same $z_{i,j}$ variables. These constraints are convenient for enforcing connectivity of a defined set of *terminal nodes* to the root node. A detailed description of these constraints including improvements like *back cuts* and *creep flow* can be found in [15] and several other references.

The cycle breaking constraints in (3g) also combine well with the cycle-based DC OPF ICI formulation in (2). To apply (2), a cycle basis and optionally some additional network cycles need to be found. From these precomputed cycles, the shorter ones (e.g., with the length less than 6–8 edges) can be used to strengthen the initial model formulation with some constraints of type (3g).

4. MILP heuristics

When solving (6), no feasible solution could be found within the optimization time limit for several larger instances. In practice, it is highly beneficial to obtain an initial feasible solution as early as possible because this would increase the available time to improve the upper bound of (6) using various efficient techniques available in the modern MIP solvers. As the practice has shown that multiple MILP heuristics available in Gurobi [18] often cannot retrieve a feasible solution, a new problem-specific heuristic had to be proposed to improve the solvability of (1) and (6). This heuristic is outlined in Algorithm 2.

Algorithm 2 MILP heuristic for initialization of DC OPF ICL.

Input: $x_{i,k}^{LP}, \mathcal{V}, \mathcal{E}, \mathcal{R}, K$
Output: $x_{i,k}^*, y_{i,j}^*, z_{i,j}^*$

```

1:  $\mathcal{E}^{on} \leftarrow \emptyset$ 
2: for  $k = 1, \dots, K$  do
3:   for  $(i, j) \in \mathcal{E}$  do
4:     if  $x_{i,k}^{LP} > 0.9 \wedge x_{j,k}^{LP} > 0.9$  then  $\mathcal{E}^{on} \leftarrow \mathcal{E}^{on} \cup (i, j)$ 
5:   end if
6: end for
7: end for
8:  $CC \leftarrow \text{connected\_components}(G(\mathcal{V}, \mathcal{E}^{on}))$ 
9:  $\mathcal{P} \leftarrow \emptyset$  // Set of partial islands
10: for  $CC \in CC$  do
11:    $r \leftarrow \mathcal{R} \cap CC$ 
12:   if  $|r| = 0$  then continue
13:   else if  $|r| \geq 2$  then return  $\emptyset$ 
14:   else  $\mathcal{P} \leftarrow \mathcal{P} \cup CC$ 
15:   end if
16: end for
17: if  $\frac{\sum_{P \in \mathcal{P}} |P|}{n} \geq 0.8$  then
18:   Fix  $x_{i,k}, y_{i,j}, z_{i,j}$  according to  $\mathcal{P}$  and solve the reduced MILP
   (e.g., (1)) with more than 80% fixed buses.
19: end if
20: return The solution of reduced MILP  $x_{i,k}^*, y_{i,j}^*, z_{i,j}^*$ 

```

The LR of $x_{i,k}$ is taken as input and analyzed in lines 2–7 to identify the edges that are considered to be closed by the current LR. Then these edges are used to build an undirected graph G in line 8, and the connected components of that graph are identified. Next, each connected component is analyzed for the presence of a root node $r \in \mathcal{R}$ in it. If a root node is present in the component, it is saved to the set of *partial islands* \mathcal{P} . Finally, the $x_{i,k}$ variables of the nodes belonging to contiguous partial islands are fixed, and the values of the remaining node variables are obtained by solving the initial problem as MILP with the majority of discrete variables being fixed. Because of a high degree of reduction of discrete variables, the reduced MILP is usually solved in a fraction of a second. However, it is important to find connected partial islands, as just rounding the LR will very often result in infeasibility.

The heuristic in Algorithm 2 is only run until a feasible solution becomes available, as modern MILP solvers are able to apply more efficient heuristics to consistently improve the existing solution.

5. Computational results

5.1. Test setup

This section¹ presents a comparison of the proposed formulation in (6) to the known benchmark model in (1). The results are produced for a number of test networks from the MATPOWER toolbox [19]. As publicly available power system test cases do not include coherent generator groupings that are required in (1c), those were obtained with the generator coherency algorithm from [20] for every test case. For the MATPOWER test cases lacking the dynamic generator data it was fitted from [21].

Three test cases from MATPOWER were selected to evaluate the proposed formulation: *case89pegase*, *case1354pegase*, and *case1888rte*. The 89 bus test case was selected because it posed some difficulties for the MILP solver despite its moderate size, while the 1354 and 1888 bus test cases are examples of large-scale networks.

Table 1

Load shedding minimization using (1).

n	K	UB , p.u.	g , % T , s	P_{LS} , p.u.	P_{Δ} , p.u.	P_{GS} , p.u.	p_{ij}^{Σ} , p.u.
89	2	6.4089	47%	5.02	11.4	6.4	13.3
89	3	8.3011	46%	5.02	11.4	6.4	32.2
89	4	13.844	64%	10.2	21.9	11.6	34.9
89	5	13.876	70%	10.2	21.9	11.6	35.2
1354	2	2.3878	0.5 s	−0.00	16.6	16.6	22.2
1354	3	4.6645	100 s	−0.00	16.6	16.6	45
1354	4	3.3921	1 s	−0.00	16.6	16.6	32.3
1354	5	8.3761	20%	−0.00	16.6	16.6	82.1
1354	6	12	12%	0.03	16.7	16.7	118
1354	7	13.631	14%	0.01	16.7	16.6	135
1354	8	21.148	33%	1.58	19.8	18.2	194
1888	2	0.4949	0.8 s	−0.00	9.81	9.81	3.97
1888	3	11.38	51%	0.08	9.81	9.88	112
1888	4	4.5363	11%	−0.00	9.81	9.81	44.4
1888	5	7.0738	14%	−0.00	9.81	9.81	69.8
1888	6	9.2755	10%	0.02	9.85	9.83	91.5
1888	7	16.976	40%	0.17	9.94	9.97	167
1888	8	12.457	17%	−0.00	9.81	9.81	124

All computations were performed using Gurobi v. 9.1. [18] on a PC with an Intel® Core™ i7 2.20 GHz CPU with 6 cores and 16 Gb of RAM running on Windows 10. The reported solution times include the presolve and MILP solver time, but exclude the model preparation time, which is polynomial. The time limit for the test cases with less than 500 buses has been set to 480 s and to 720 s for the test cases with more than 500 buses. In all the experiments, the default Gurobi solver settings were used. The maximal time to be spent in the MILP heuristic from Section 4 is set to 3% of the time limit. For simplicity, the auxiliary MILP model in Algorithm 2 is based on (1) for all test cases. The solution was considered optimal if its MIP optimality gap was less than 1%.

5.2. Minimization of load shedding

The first set of test results is related to minimizing the known objective in (1a). The objective weights are set as follows: $\alpha = 0$, $\beta = 1$, $\gamma = 0.01$, $\mu = 0.1$. The relatively high value of μ is selected mainly to ensure non-zero lower bounds in all cases and thus a more informative progression of the MIP optimality gap during the optimization. The big-M coefficients $M_{i,j}^{\varphi}$ in (6) are set to 2π , φ^{min} is set to $-\pi$, φ^{max} is set to π , and the power flow limitation p_{ij}^{max} is assumed to be equal to $b_{i,j}\pi/4$, $\forall (i,j) \in \mathcal{E}$.

First, the results for the baseline formulation in (1) are presented in Table 1. The table header can be read as follows: UB is the best MIP objective value (i.e., the upper bound), g is the final optimality gap, T is the solution time, P_{LS} , P_{Δ} , P_{GS} , p_{ij}^{Σ} are the final values of load shedding, total power imbalance, generator shedding, and power flow cut respectively. In Table 1, g and T are included interchangeably: if g is less than the optimality tolerance then T is included, otherwise g is shown, as T equals to the time limit.

Next, in the formulation in (1) the flow-based connectivity constraints (1p)–(1s) are replaced with (3) and the MILP heuristic is enabled. The results obtained after this modification are summarized in Table 2. Finally, the results of our complete formulation in (6) with the MILP heuristic enabled for the given cost function are given in Table 3.

As it can be seen, the results in Tables 2–3 in terms of the MIP optimality gap and solution time usually exceed those in Table 1, which demonstrates the efficacy of the proposed improvements.

5.3. Minimization of total power imbalance

To complement Section 5.2, the same test cases are recomputed with the main objective of power imbalance minimization. The objective

¹ The code implementation can be found at https://github.com/ityuryukanov/power_network_clustering under .papers/PSCC_2022.

Table 2
Load shedding minimization using (1) and (3).

n	K	UB , p.u.	g , % T , s	P_{LS} , p.u.	P_d , p.u.	P_{GS} , p.u.	p_{ij}^x , p.u.
89	2	6.4089	49%	5.02	11.4	6.4	13.3
89	3	8.3011	46%	5.02	11.4	6.4	32.2
89	4	13.844	65%	10.2	21.9	11.6	34.9
89	5	13.876	68%	10.2	21.9	11.6	35.2
1354	2	2.3878	0.5 s	−0.00	16.6	16.6	22.2
1354	3	4.6645	80 s	−0.00	16.6	16.6	45
1354	4	3.3921	1.1 s	−0.00	16.6	16.6	32.3
1354	5	8.1682	16%	−0.00	16.6	16.6	80
1354	6	12	12%	0.03	16.7	16.7	118
1354	7	13.453	13%	0.03	16.7	16.7	133
1354	8	20.278	30%	0.29	17.2	16.9	198
1888	2	0.4949	1 s	−0.00	9.81	9.81	3.97
1888	3	9.0864	39%	0.01	9.82	9.81	89.8
1888	4	4.5119	10%	−0.00	9.81	9.81	44.1
1888	5	7.0672	14%	−0.00	9.81	9.81	69.7
1888	6	9.3695	12%	−0.00	9.81	9.81	92.7
1888	7	14.329	28%	−0.00	9.81	9.81	142
1888	8	12.158	15%	0.00	9.81	9.81	121

Table 3
Load shedding minimization using (6).

n	K	UB , p.u.	g , % T , s	P_{LS} , p.u.	P_d , p.u.	P_{GS} , p.u.	p_{ij}^x , p.u.
89	2	6.4089	57%	5.02	11.4	6.4	13.3
89	3	8.3011	57%	5.02	11.4	6.4	32.2
89	4	11.254	64%	5.9	13.2	7.28	52.9
89	5	11.096	62%	5.9	13.2	7.28	51.3
1354	2	2.3878	0.5 s	−0.00	16.6	16.6	22.2
1354	3	4.6645	55 s	−0.00	16.6	16.6	45
1354	4	3.3921	1.1 s	−0.00	16.6	16.6	32.3
1354	5	8.1682	17%	−0.00	16.6	16.6	80
1354	6	12	11%	0.03	16.7	16.7	118
1354	7	13.441	13%	−0.00	16.6	16.6	133
1354	8	18.420	21%	0.24	17.1	16.9	180
1888	2	0.4949	0.6 s	−0.00	9.81	9.81	3.97
1888	3	11.876	33%	−0.00	9.81	9.81	118
1888	4	4.5116	590 s	−0.00	9.81	9.81	44.1
1888	5	7.0534	9%	−0.00	9.81	9.81	69.6
1888	6	9.275	11%	0.02	9.85	9.83	91.5
1888	7	14.163	26%	−0.00	9.81	9.81	141
1888	8	12.16	13%	−0.00	9.81	9.81	121

weights are set as follows: $\alpha = 1$, $\beta = 0.01$, $\gamma = 0.01$, $\mu = 0.01$. Now the highest priority is given to generation-load imbalance minimization, with load shedding being included with a small weight. As the initial power imbalance is nearly always substantially higher than zero after the network is split, non-zero lower bounds can be produced without assigning an increased value to μ .

The results comparison follows the same route as in Section 5.2. The results of minimizing the new objective with the formulation in (1) are listed in Table 4. The outcome of the exchange of (1p)–(1s) with (3) is illustrated in Table 5. Finally, the results of our formulation in (6) are shown in Table 6.

As it can be seen from Table 4, with the change of the objective function more cases fail to compute at least a feasible solution with the basic formulation (1). Thus, the role of feasibility MILP heuristics becomes larger. In fact, the proposed MILP heuristic is enabled for the results in Tables 5–6, and feasibility is achieved for all the test cases. The performance is also improved with the proposed enhancements, which can be seen by comparing the 4th columns of Tables 4–6.

An additional important observation can be made by comparing the upper bounds of *case89pegase* across Tables 4–6. Although the optimal solution could be reached in all cases, the optimal value is better with our complete formulation (6). This is explained by the absence of big-M constraints in (6), the values for which must be selected. Thus, (6)

Table 4
Islands' power imbalance minimization using (1).

n	K	UB , p.u.	g , % T , s	P_{LS} , p.u.	P_d , p.u.	P_{GS} , p.u.	p_{ij}^x , p.u.
89	2	7.8621	5 s	3.09	6.24	4.47	55.5
89	3	8.0531	33 s	3.09	6.24	4.47	74.6
89	4	14.807	13 s	8.77	11.1	10.1	66.6
89	5	14.809	16 s	8.77	11.1	10.1	66.9
1354	2	17.023	0.5 s	−0.00	16.6	16.6	22.2
1354	3	17.272	11 s	−0.00	16.6	16.6	47.1
1354	4	17.124	1.7 s	−0.00	16.6	16.6	32.3
1354	5	17.684	580 s	−0.00	16.6	16.6	88.3
1354	6	–	–	–	–	–	–
1354	7	–	–	–	–	–	–
1354	8	–	–	–	–	–	–
1888	2	9.9447	1.2 s	−0.00	9.81	9.81	3.97
1888	3	–	–	–	–	–	–
1888	4	10.427	23 s	−0.00	9.81	9.81	52.2
1888	5	10.603	94 s	−0.00	9.81	9.81	69.8
1888	6	10.896	120 s	−0.00	9.81	9.81	99.1
1888	7	–	–	–	–	–	–
1888	8	–	–	–	–	–	–

Table 5
Power imbalance minimization using (1) and (3).

n	K	UB , p.u.	g , % T , s	P_{LS} , p.u.	P_d , p.u.	P_{GS} , p.u.	p_{ij}^x , p.u.
89	2	7.8621	13 s	3.09	6.24	4.47	55.5
89	3	8.0531	85 s	3.09	6.24	4.47	74.6
89	4	14.807	13 s	8.77	11.1	10.1	66.6
89	5	14.809	15 s	8.77	11.1	10.1	66.9
1354	2	17.023	0.6 s	−0.00	16.6	16.6	22.2
1354	3	17.32	19 s	−0.00	16.6	16.6	51.9
1354	4	17.123	1.5 s	−0.00	16.6	16.6	32.3
1354	5	17.72	90 s	0.07	16.6	16.7	89.6
1354	6	18.001	220 s	−0.00	16.6	16.6	120
1354	7	18.162	410 s	−0.00	16.6	16.6	136
1354	8	18.628	1.1%	0.00	16.6	16.6	183
1888	2	9.9447	1 s	−0.00	9.81	9.81	3.97
1888	3	11.135	3.5%	−0.00	9.81	9.81	123
1888	4	10.374	36 s	−0.00	9.81	9.81	46.9
1888	5	10.688	280 s	−0.00	9.81	9.81	78.3
1888	6	10.897	280 s	0.02	9.85	9.83	93.8
1888	7	11.301	170 s	−0.00	9.81	9.81	140
1888	8	11.211	1.1%	−0.00	9.81	9.81	131

can be certain to achieve the true optimal solution. In the present case study, it is possible to achieve the same optimum using (1) if the angular big-M constraints are substantially increased (e.g., by a factor of 10).

6. Conclusions

This paper has proposed several computational enhancements to the DC OPF ICI problem. The main idea was to eliminate the big-M constants that are present in the most existing formulations in order to tighten the linear relaxation of DC OPF ICI. The big-M constants present in island connectivity constraints have been removed by replacing the popular single commodity flow based connectivity model with the new model based on directed spanning forests, which does not require any large coefficients. The big-M constants associated with ICI switching decisions and DC OPF in general have been excluded by replacing the DC OPF switching constraints based on Ohm's law with the new ones based on KVL.

Besides of handling of all the three types of big-M constants in the standard DC OPF ICI formulation, it has also been observed that the existing ICI objective functions may not fully correspond to the practical requirements associated with system splitting. To ameliorate this, the new objective function minimizing the load-generation imbalance

Table 6
Islands' power imbalance minimization using (6).

n	K	UB , p.u.	g , % T , s	P_{LS} , p.u.	P_d , p.u.	P_{GS} , p.u.	p_{ij}^z , p.u.
89	2	7.6364	19 s	2.43	6.24	3.81	55.5
89	3	7.8258	52 s	2.43	6.24	3.81	74.4
89	4	13.485	12 s	4.88	11.1	6.26	66.6
89	5	13.488	12 s	4.88	11.1	6.26	66.9
1354	2	17.023	0.4 s	−0.00	16.6	16.6	22.2
1354	3	17.38	11 s	−0.00	16.6	16.6	57.9
1354	4	17.123	1.0 s	−0.00	16.6	16.6	32.3
1354	5	17.604	76 s	−0.00	16.6	16.6	80.3
1354	6	18.089	180 s	−0.00	16.6	16.6	129
1354	7	21.668	17%	1.42	19.5	18.1	155
1354	8	18.565	350 s	−0.00	16.6	16.6	176
1888	2	9.9447	0.5 s	−0.00	9.81	9.81	3.97
1888	3	10.821	65 s	−0.00	9.81	9.81	91.7
1888	4	10.431	6.7 s	0.03	9.87	9.84	45.1
1888	5	10.68	79 s	−0.00	9.81	9.81	77.5
1888	6	10.92	170 s	−0.00	9.81	9.81	101
1888	7	11.298	150 s	−0.00	9.81	9.81	139
1888	8	11.208	283 s	−0.00	9.81	9.81	131

after splitting has been introduced. With this objective, situations when the MIP solver cannot find an initial feasible solution have become more common. To fix this, a new MILP heuristic for DC OPF ICI has been proposed as well. In general, the solution process was noticeably influenced by the type of objective function. Thus, it could be possible to choose “convenient” objective functions to quickly find feasible initial solutions.

Finally, the proposed enhancements have been tested against the compact and efficient baseline DC ICI OPF model from the literature, and it has been found that the novel ICI model produces better results in most of cases. In the future, it is planned to apply the findings of this paper to more complex and accurate ICI models and possibly to other transmission switching problems.

CRediT authorship contribution statement

Ilya Tyuryukanov: Methodology, Software, Validation, Investigation, Writing – original draft, Writing – review & editing. **Marjan Popov:** Conceptualization, Investigation, Resources, Writing – original draft, Writing – review & editing, Supervision, Project administration, Funding acquisition. **Jorrit A. Bos:** Conceptualization, Investigation, Writing – original draft, Writing – review & editing, Supervision. **Mart A.M.M. van der Meijden:** Conceptualization, Resources, Funding acquisition. **Vladimir Terzija:** Conceptualization, Writing – review & editing.

Declaration of competing interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Acknowledgments

This work was financially supported by the Dutch Scientific Council NWO in collaboration with TSO TenneT, DSOs Alliander, Stedin, Enduris, VSL and General Electric in the framework of the Energy

System Integration & Big Data program under the project “Resilient Synchroreasurement-based Grid Protection Platform, no. 647.003.004”.

All authors have read and agreed to the submitted version of the manuscript.

References

- [1] H.H. Alhelou, M.E. Hamedani-Golshan, T.C. Njenda, P. Siano, A survey on power system blackout and cascading events: Research motivations and challenges, *Energies* 12 (4) (2019) 682.
- [2] P.A. Trodden, W.A. Bukhsh, A. Grothey, et al., Optimization-based islanding of power networks using piecewise linear AC power flow, *IEEE Trans. Power Syst.* 29 (3) (2014) 1212–1220.
- [3] W.E. Brown, E. Moreno-Centeno, Transmission-line switching for load shed prevention via an accelerated linear programming approximation of AC power flows, *IEEE Trans. Power Syst.* 35 (4) (2020) 2575–2585.
- [4] C. Coffrin, P. Hentenryck, Transmission system restoration with co-optimization of repairs, load pickups, and generation dispatch, *Int. J. Electr. Power Energy Syst.* 72 (2015) 144–154.
- [5] N. Fan, D. Izraelevitz, F. Pan, P.M. Pardalos, J. Wang, A mixed integer programming approach for optimal power grid intentional islanding, *Energy Syst.* 3 (2012) 77–93.
- [6] F. Teymouri, T. Amraee, H. Saberi, F. Capitanescu, Toward controlled islanding for enhancing power grid resilience considering frequency stability constraints, *IEEE Trans. Smart Grid* 10 (2) (2017) 1735–1746.
- [7] P.A. Trodden, W.A. Bukhsh, A. Grothey, K.I.M. McKinnon, MILP formulation for controlled islanding of power networks, *Int. J. Electr. Power Energy Syst.* 45 (1) (2013) 501–508.
- [8] R.A. Jabr, Polyhedral formulations and loop elimination constraints for distribution network expansion planning, *IEEE Trans. Power Syst.* 28 (2) (2013) 1888–1897.
- [9] B. Kocuk, H. Jeon, S.S. Dey, J. Linderroth, J. Luedtke, A. Sun, A cycle-based formulation and valid inequalities for DC power transmission problems with switching, *Oper. Res.* 64 (4) (2016) 922–938.
- [10] A. Kyriacou, P. Demetriou, C. Panayiotou, E. Kyriakides, Controlled islanding solution for large-scale power systems, *IEEE Trans. Power Syst.* 33 (2) (2017) 1591–1602.
- [11] G. Patsakis, D. Rajan, I. Aravena, S. Oren, Strong mixed-integer formulations for power system islanding and restoration, *IEEE Trans. Power Syst.* 34 (6) (2019) 4880–4888.
- [12] L. Ding, F.M. Gonzalez-Longatt, P. Wall, V. Terzija, Two-step spectral clustering controlled islanding algorithm, *IEEE Trans. Power Syst.* 28 (1) (2013) 75–84.
- [13] S. Fattahi, J. Lavaei, A. Atamtürk, A bound strengthening method for optimal transmission switching in power systems, *IEEE Trans. Power Syst.* 34 (1) (2019) 280–291.
- [14] I. Tyuryukanov, M.A.M.M. van der Meijden, V. Terzija, M. Popov, Spectral MST-Based Graph Outlier Detection with Application to Clustering of Power Networks, in: *Proc. 2018 Power Systems Computation Conference (PSCC)*, 2018, pp. 1–8.
- [15] S. Chopra, C.-Y. Tsai, Polyhedral approaches for the steiner tree problem on graphs, in: X.Z. Cheng, D.-Z. Du (Eds.), *Steiner Trees in Industry*, in: COOP, vol. 11, Springer, 2001, pp. 175–201.
- [16] A. Borghetti, A mixed-integer linear programming approach for the computation of the minimum-losses radial configuration of electrical distribution networks, *IEEE Trans. Power Syst.* 27 (3) (2012) 1264–1273.
- [17] C. Hojny, I. Joormann, H. Lüthen, M. Schmidt, Mixed-integer programming techniques for the connected max-k-cut problem, *Math. Program. Comput.* 13 (2021) 75–132.
- [18] Gurobi Optimizer Reference Manual, Gurobi Optimization, LLC, 2020, [Online]. Available: <http://www.gurobi.com>.
- [19] S. Fliscounakis, P. Panciatici, F. Capitanescu, L. Wehenkel, Contingency ranking with respect to overloads in very large power systems taking into account uncertainty, preventive, and corrective actions, *IEEE Trans. Power Syst.* 28 (4) (2013) 4909–4917.
- [20] I. Tyuryukanov, M. Popov, M. van der Meijden, V. Terzija, Slow coherency identification and power system dynamic model reduction by using orthogonal structure of electromechanical eigenvectors, *IEEE Trans. Power Syst.* 36 (2) (2021) 1482–1492.
- [21] P.M. Anderson, A.A. Fouad, *Power System Control and Stability*, second ed., in: IEEE Press power engineering series, IEEE Press and Wiley-Interscience, Piscataway, N.J., 2003.