

Aquifer thermal energy storage triplet: Moving towards self-sufficient space heating and cooling

van Esch, M.S.; Bloemendal, Martin; Hartog, Niels; Vardon, P.J.

Publication date

2022

Document Version

Final published version

Citation (APA)

van Esch, M. S., Bloemendal, M., Hartog, N., & Vardon, P. J. (2022). *Aquifer thermal energy storage triplet: Moving towards self-sufficient space heating and cooling*. 49-49. Abstract from 13th European Geothermal PhD Days - 2022, Aachen, North Rhine-Westphalia, Germany.

Important note

To cite this publication, please use the final published version (if applicable). Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights. We will remove access to the work immediately and investigate your claim.

13th European Geothermal PhD Days 2022

Posters
Fieldtrip
Workshops

Social event
Networking
and more!

27th - 29th April 2022
RWTH Aachen, Germany

Organized by:

RWTHAACHEN
UNIVERSITY

TUDelft

ETH zürich



POLITECNICO
MILANO 1863



EASYGO ITN

Aquifer thermal energy storage triplet: Moving towards self-sufficient space heating and cooling.

Matthijs S. van Esch¹, Martin Bloemendal^{1,2}, Niels Hartog², Philip J. Vardon¹

¹ Delft University of Technology, Delft, The Netherlands

² KWR Water Research, Nieuwegein, The Netherlands

Aquifer Thermal Energy Storage (ATES) is mostly used to store heat and cold in groundwater at relatively low temperatures for heating and cooling buildings. These systems emit 3-4 times less CO₂ when compared to gas heating, but still require substantial amounts of electricity to run due to the use of a heat pump (60%). In typical ATES systems in the Netherlands, when there is a cooling demand, groundwater is pumped from the cold well for cooling, raising the temperature of the water to 18°C which is then injected in the warm well. When there is a heating demand water is pumped from the warm storage well and concentrated using a heat pump to the required heating temperature of the building (40-50°C). This process typically cools down the water to 7°C which is then injected into the cold well.

Storing groundwater at a temperature that matches the required heating and cooling temperature can reduce or eliminate the need for a heat pump. This can be achieved by using sustainable sources to supply the heat and cold from the environment (e.g. solar panels, dry coolers). However, the availability of these sources can be insufficient to reach the required temperature level. Therefore a third well is added where water at the return temperature after building heating or cooling is stored, until it can be again heated or cooled to temperatures matching the demand. This is the concept of an ATES triplet.

Initial simulations are presented which show a factor of 10 reductions in CO₂ emissions compared to conventional systems, while the systems are calculated to have an improved economic performance, although require a higher initial investment. Further research will investigate the subsurface and above ground system layout and operational conditions which impact the economic and environmental performance (CO₂, thermal efficiency and pollution).