

## Effects of topology on water distribution systems resilience

Cassottana, Beatrice; Aydin, Nazli Yonca; Tang, Loon Ching

**DOI**

[10.3850/978-981-14-8593-0\\_3865-cd](https://doi.org/10.3850/978-981-14-8593-0_3865-cd)

**Publication date**

2020

**Document Version**

Final published version

**Published in**

Proceedings of the 30th European Safety and Reliability Conference and the 15th Probabilistic Safety Assessment and Management Conference

**Citation (APA)**

Cassottana, B., Aydin, N. Y., & Tang, L. C. (2020). Effects of topology on water distribution systems resilience. In P. Baraldi, F. Di Maio, & E. Zio (Eds.), *Proceedings of the 30th European Safety and Reliability Conference and the 15th Probabilistic Safety Assessment and Management Conference* (pp. 1042). (Proceedings of the 30th European Safety and Reliability Conference and the 15th Probabilistic Safety Assessment and Management Conference). Research Publishing. [https://doi.org/10.3850/978-981-14-8593-0\\_3865-cd](https://doi.org/10.3850/978-981-14-8593-0_3865-cd)

**Important note**

To cite this publication, please use the final published version (if applicable). Please check the document version above.

**Copyright**

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

**Takedown policy**

Please contact us and provide details if you believe this document breaches copyrights. We will remove access to the work immediately and investigate your claim.

# EFFECTS OF TOPOLOGY ON WATER DISTRIBUTION SYSTEMS RESILIENCE

BEATRICE CASSOTTANA<sup>1</sup>, NAZLI YONCA AYDIN<sup>2</sup>, LOON CHING TANG<sup>3</sup>

<sup>1</sup>*Future Resilient Systems, Singapore-ETH center, Singapore.*

*E-mail: beatrice.cassottana@frs.ethz.ch*

<sup>2</sup>*Faculty of Technology, Policy and Management, Delft University of Technology, The Netherlands. E-mail: n.y.aydin@tudelft.nl*

<sup>3</sup>*Department of Industrial Systems Engineering and Management, National University of Singapore. E-mail: isetlc@nus.edu.sg*

Water Distribution Systems (WDSs) are critical infrastructures for providing water to sustain life and human activities. Some recent trends, such as climate change, urbanization, and increasing system interdependence, have led to more frequent threats, with detrimental effects on WDSs. In recent years, resilience has been considered an effective approach to address those threats, for which it is difficult to estimate the likelihood and consequences (Henry and Ramirez-Marquez, 2012). In the literature, two approaches were used to assess WDS resilience. On the one hand, performance-based metrics were used to quantify the impacts of disruptions on the WDS. Specifically, recovery functions were developed to model the time-continuous system response following a disruption, during periods of loss and restoration of performance (Cassottana et al., 2019). On the other hand, indexes based on system attributes were developed to classify WDSs and identify structural vulnerabilities. For example, algebraic connectivity, clustering coefficient, and average path length were used as proxies for robustness, redundancy, and efficiency, respectively (Yazdani et al., 2011). However, those approaches were applied separately, and the relationship between the performance of WDSs and their attributes is still unknown. Hence, the question arises from the above analysis on how to identify the key structural factors determining the resilience of a WDS.

The goal of this research is to understand how and to what extent different network topologies determine different performance losses and recovery behaviors given increasing magnitude of disruption, i.e., pipe breakdown. To this end, we consider different network topologies as case studies and vary their structural attributes, e.g., water source head and tank capacity. We then simulate disruption scenarios of increasing magnitude and model the resulting system performance by means of recovery functions for the assessment of resilience. The estimated parameters of these functions are useful for characterizing different system responses, including severe or limited performance losses and fast or slow recoveries. By systematically varying the network topologies and the structural attributes, the function parameters could be in turn associated with key structural factors. We find that, while increasing the WDS supply capacity results in limited performance loss in terms of satisfied demand for water, increasing the reserve capacity improves the robustness of the system by delaying the loss of performance. This analysis will inform the design of resilient water networks based on their topology and unique attributes.

*Keywords:* Resilience, Topology, Recovery Functions, Water Distribution System, pipe failure.

## References

- Cassottana, B., Shen, L., & Tang, L. C. (2019). Modeling the recovery process: A key dimension of resilience. *Reliability Engineering & System Safety*, 190, 106528.
- Henry, D., Ramirez-Marquez, J. E. (2012). Generic metrics and quantitative approaches for system resilience as a function of time. *Reliability Engineering & System Safety* 99, 114–122.
- Yazdani, A., Otoo, R. A., & Jeffrey, P. (2011). Resilience enhancing expansion strategies for water distribution systems: A network theory approach. *Environmental Modelling & Software* 26(12), 1574-1582.

*Proceedings of the 30th European Safety and Reliability Conference and the 15th Probabilistic Safety Assessment and Management Conference*  
Edited by Piero Baraldi, Francesco Di Maio and Enrico Zio

Copyright © ESREL2020-PSAM15 Organizers. Published by Research Publishing, Singapore.

ISBN: 978-981-14-8593-0; doi:10.3850/978-981-14-8593-0\_3865-cd